

19. 施設耐震化状況及び災害時確保水量(上水道)

地方 事務所	番号	事業体名	浄水場耐震化状況 (m ³ /日)						配水池耐震化状況 (m ³ /日)					
			総浄水 能力 (m ³ /日)	L2対応済み		L2未対応		うち未確認		総有効 容量 (m ³ / 日)	対応済み (ランクAのみ)		対応済み (ランクB含む)	
				浄水 能力 (m ³ / 日)	割合 (%)	浄水 能力 (m ³ / 日)	割合 (%)	浄水 能力 (m ³ / 日)	割合 (%)		有効 容量 (m ³ / 日)	割合 (%)	有効 容量 (m ³ / 日)	割合 (%)
佐久	6	小諸市	18,178	0	0.0	1,340	7.4	16,838	92.6	21,109	4,020	19.0	4,020	19.0
	42	小海町	6,105	0	0.0	6,105	100.0	0	0.0	4,158	4,158	100.0	4,158	100.0
	13	軽井沢町	23,270	0	0.0	23,070	99.1	200	0.9	10,621	0	0.0	0	0.0
	90	御代田町	2,820	2,220	78.7	0	0.0	600	21.3	3,097	3,097	100.0	3,097	100.0
	50	立科町	5,785	0	0.0	0	0.0	5,785	100.0	3,782	0	0.0	0	0.0
	37	佐久水道企業団	42,857	9,650	22.5	21,960	51.2	11,247	26.2	28,813	14,000	48.6	14,000	48.6
	86	(株)ハヶ岳高原ロッジ	3,292	0	0.0	0	0.0	3,292	100.0	1,588	0	0.0	0	0.0
		計	102,307	11,870	11.6	52,475	51.3	37,962	37.1	73,168	25,275	34.5	25,275	34.5
上小	3	上田市	65,500	0	0.0	65,500	100.0	0	0.0	35,190	14,100	40.1	14,100	40.1
	44	上田市(丸子地区)	15,200	8,200	53.9	0	0.0	7,000	46.1	7,474	500	6.7	500	6.7
	67	上田市(真田地区)	8,000	0	0.0	0	0.0	8,000	100.0	8,000	0	0.0	500	6.3
	53	東御市	13,400	1,059	7.9	0	0.0	12,341	92.1	19,786	117	0.6	117	0.6
		計	102,100	9,259	9.1	65,500	64.2	27,341	26.8	70,450	14,717	20.9	15,217	21.6
諏訪	14	岡谷市	32,200	200	0.6	10,900	33.9	21,100	65.5	13,986	4,841	34.6	4,841	34.6
	5	諏訪市	42,400	0	0.0	0	0.0	42,400	100.0	17,638	8,450	47.9	8,450	47.9
	45	茅野市	31,800	2,199	6.9	27,443	86.3	2,158	6.8	18,706	1,500	8.0	1,500	8.0
	55	茅野市(蓼科地区)	5,400	0	0.0	5,400	100.0	0	0.0	1,407	0	0.0	0	0.0
	65	茅野市(白樺湖地区)	4,100	0	0.0	3,775	92.1	325	7.9	993	0	0.0	0	0.0
	17	下諏訪町	20,420	10,000	49.0	0	0.0	10,420	51.0	6,250	0	0.0	0	0.0
	58	富士見町	20,600	9,580	46.5	7,840	38.1	3,180	15.4	24,521	10,620	43.3	10,620	43.3
	56	原村	4,500	975	21.7	0	0.0	3,525	78.3	4,550	1,432	31.5	1,432	31.5
	71	東洋観光事業(株)	3,200	0	0.0	0	0.0	3,200	100.0	2,866	0	0.0	0	0.0
	78	(株)蓼科ビレッジ	4,450	0	0.0	0	0.0	4,450	100.0	2,919	0	0.0	0	0.0
	79	(株)三井の森	2,194	0	0.0	0	0.0	2,194	100.0	1,190	0	0.0	0	0.0
	80	東急不動産(株)	3,400	0	0.0	0	0.0	3,400	100.0	2,370	0	0.0	0	0.0
	85	鹿島リゾート(株)	2,045	0	0.0	0	0.0	2,045	100.0	3,190	0	0.0	0	0.0
	計	176,709	22,954	13.0	55,358	31.3	98,397	55.7	100,586	26,843	26.7	26,843	26.7	
上伊那	35	伊那市	32,004	2,160	6.7	800	2.5	29,044	90.8	30,122	2,331	7.7	2,974	9.9
	29	駒ヶ根市	10,840	8,421	77.7	2,419	22.3	0	0.0	10,507	7,196	68.5	7,752	73.8
	25	辰野町	9,500	63	0.7	0	0.0	9,437	99.3	4,706	1,508	32.0	1,508	32.0
	59	箕輪町	3,360	0	0.0	3,360	100.0	0	0.0	7,480	2,000	26.7	2,000	26.7
	66	飯島町	5,961	0	0.0	5,961	100.0	0	0.0	5,465	4,200	76.9	4,200	76.9
	64	南箕輪村	1,500	1,500	100.0	0	0.0	0	0.0	3,073	3,073	100.0	3,073	100.0
	88	中川村	2,265	0	0.0	0	0.0	2,265	100.0	1,833	0	0.0	1,833	100.0
	52	宮田村	4,000	0	0.0	0	0.0	4,000	100.0	3,000	0	0.0	0	0.0
		計	69,430	12,144	17.5	12,540	18.1	44,746	64.4	66,186	20,308	30.7	23,340	35.3
下伊那	70	飯田市	44,409	500	1.1	43,909	98.9	0	0.0	37,864	15,415	40.7	25,283	66.8
	83	松川町	4,800	0	0.0	0	0.0	4,800	100.0	2,805	0	0.0	0	0.0
	76	高森町	4,500	0	0.0	0	0.0	4,500	100.0	1,578	0	0.0	0	0.0
		計	53,709	500	0.9	43,909	81.8	9,300	17.3	42,247	15,415	36.5	25,283	59.8
木曾	20	木曾町	4,085	0	0.0	4,085	100.0	0	0.0	2,575	0	0.0	0	0.0
		計	4,085	0	0.0	4,085	100.0	0	0.0	2,575	0	0.0	0	0.0

地方 事務所	番号	事業体名	浄水場耐震化状況 (m ³ /日)							配水池耐震化状況 (m ³ /日)					
			総浄水 能力 (m ³ /日)	L2対応済み		L2未対応			うち未確認	総有効 容量 (m ³ / 日)	対応済み (ランクAのみ)		対応済み (ランクB含む)		
				浄水 能力 (m ³ / 日)	割合 (%)	浄水 能力 (m ³ / 日)	割合 (%)	浄水 能力 (m ³ / 日)			割合 (%)	有効 容量 (m ³ / 日)	割合 (%)	有効 容量 (m ³ / 日)	割合 (%)
松本	4	松本市(松本地区)	19,057	0	0.0	0	0.0	19,057	100.0	65,737	6,000	9.1	6,484	9.9	
	41	松本市(梓川地区)	7,844	1,540	19.6	0	0.0	6,304	80.4	7,827	5,100	65.2	5,100	65.2	
	47	松本市(四賀地区)	2,360	2,100	89.0	0	0.0	260	11.0	3,421	1,000	29.2	1,000	29.2	
	19	松本市(波田地区)	9,020	4,887	54.2	0	0.0	4,133	45.8	6,328	5,000	79.0	5,000	79.0	
	46	塩尻市	19,720	19,720	100.0	0	0.0	0	0.0	32,708	25,422	77.7	25,422	77.7	
	89	安曇野市	43,500	32,085	73.8	0	0.0	11,415	26.2	20,412	25,101	123.0	16,894	82.8	
	32	山形村	2,200	0	0.0	0	0.0	2,200	100.0	3,316	0	0.0	0	0.0	
		計	103,701	60,332	58.2	0	0.0	43,369	41.8	139,749	67,623	48.4	59,900	42.9	
北安曇	9	大町市	18,000	504	2.8	0	0.0	17,496	97.2	7,370	2,496	33.9	7,370	100.0	
	22	池田町	6,000	0	0.0	5,400	90.0	600	10.0	4,128	0	0.0	4,128	100.0	
	74	松川村	4,500	0	0.0	0	0.0	4,500	100.0	2,514	0	0.0	0	0.0	
	63	白馬村	21,500	0	0.0	0	0.0	21,500	100.0	13,067	0	0.0	0	0.0	
		計	50,000	504	1.0	5,400	10.8	44,096	88.2	27,079	2,496	9.2	11,498	42.5	
長野	57	長野県	96,800	48,800	50.4	48,000	49.6	0	0.0	52,392	33,889	64.7	33,319	63.6	
	1	長野市	126,104	66,081	52.4	4,317	3.4	55,706	44.2	111,727	36,530	32.7	37,547	33.6	
	10	須坂市	21,800	800	3.7	21,000	96.3	0	0.0	21,800	0	0.0	0	0.0	
	26	千曲市	4,300	0	0.0	0	0.0	4,300	100.0	1,047	0	0.0	0	0.0	
	15	小布施町	8,400	0	0.0	0	0.0	8,400	100.0	16,800	0	0.0	0	0.0	
	87	高山村	2,270	0	0.0	2,270	100.0	0	0.0	1,291	0	0.0	0	0.0	
	81	信濃町	8,165	0	0.0	0	0.0	8,165	100.0	3,655	0	0.0	0	0.0	
	54	飯綱町(牟礼地区)	3,610	3,610	100.0	0	0.0	0	0.0	3,964	0	0.0	0	0.0	
	75	飯綱町(三水地区)	2,850	0	0.0	0	0.0	2,850	100.0	2,000	0	0.0	0	0.0	
	計	274,299	119,291	43.5	75,587	27.6	79,421	29.0	214,676	70,419	32.8	70,866	33.0		
北信	2	中野市	22,000	0	0.0	22,000	100.0	0	0.0	12,679	6,221	49.1	6,774	53.4	
	69	中野市(豊田地区)	2,500	620	24.8	1,880	75.2	0	0.0	2,015	620	30.8	620	30.8	
	27	飯山市	10,230	0	0.0	0	0.0	10,230	100.0	10,230	0	0.0	0	0.0	
	21	山ノ内町	14,810	0	0.0	14,810	100.0	0	0.0	6,438	0	0.0	0	0.0	
	40	木島平村	2,800	500	17.9	2,300	82.1	0	0.0	2,242	500	22.3	500	22.3	
	23	野沢温泉村	11,000	0	0.0	11,000	100.0	0	0.0	5,497	0	0.0	0	0.0	
		計	63,340	1,120	1.8	51,990	82.1	10,230	16.2	39,101	7,341	18.8	7,894	20.2	
全県	計	999,680	237,974	23.8	366,844	36.7	394,862	39.5	775,817	250,437	32.3	266,116	34.3		

配水池耐震化状況 (m ³ /日)				災害時確保水量										
未対応				配水池等		井戸		緊急用貯水槽等						
				うち未確認		箇所数	飲料水・生活用水 (時間)	箇所数	飲料水・生活用水 (m ³ /時間)	水道事業者設置		自治体設置		
有効容量 (m ³ /日)	割合 (%)	有効容量 (m ³ /日)	割合 (%)	箇所数	飲料水・生活用水 (時間)					箇所数	飲料水・生活用水 (m ³ /時間)	箇所数	飲料水・生活用水 (m ³)	水道事業者管理
						箇所数	飲料水・生活用水 (m ³)	箇所数	飲料水・生活用水 (m ³)					箇所数
59,253	90.1	59,253	90.1	12	8.7	6	3,143	0	0	1	200	0	0	
2,727	34.8	2,727	34.8	5	33.8	6	147	0	0	0	0	0	0	
2,421	70.8	2,421	70.8	1	15.0	0	0	0	0	0	0	0	0	
1,328	21.0	1,328	21.0	1	14.0	0	0	0	0	0	0	0	0	
7,286	22.3	0	0.0	5	8.3	5	125	0	0	0	0	654	1,308	
3,518	17.2	1,050	5.1	15	18.0	31	0	0	0	0	0	0	0	
3,316	100.0	3,316	100.0	0	0.0	0	0	0	0	0	0	0	0	
79,849	57.1	70,095	50.2	39	98	48	3,415	0	0	1	200	654	1,308	
0	0.0	0	0.0	0	0.0	2	132	0	0	0	0	0	0	
0	0.0	0	0.0	0	0.0	3	5,400	0	0	0	0	0	0	
2,514	100.0	0	0.0	2	9.5	4	380	0	0	0	0	36	1,260	
13,067	100.0	13,067	100.0	0	0.0	5	308	0	0	0	0	0	0	
15,581	57.5	13,067	48.3	2	10	14	6,220	0	0	0	0	36	1,260	
19,073	36.4	7,023	13.4	17	17.9	1	24	0	0	0	0	0	0	
74,180	66.4	74,180	66.4	20	7.6	0	0	1	500	2	510	0	0	
21,800	100.0	0	0.0	3	5.4	14	530	0	0	0	0	0	0	
1,047	100.0	1,047	100.0	0	0.0	0	0	0	0	0	0	0	0	
16,800	100.0	0	0.0	0	0.0	0	0	0	0	0	0	0	0	
1,291	100.0	1,291	100.0	0	0.0	0	0	0	0	0	0	0	0	
3,655	100.0	3,655	100.0	0	0.0	0	0	0	0	0	0	0	0	
3,964	100.0	3,964	100.0	0	0.0	5	82	0	0	0	0	0	0	
2,000	100.0	2,000	100.0	0	0.0	0	0	0	0	0	0	0	0	
143,810	67.0	93,160	43.4	40	31	20	636	1	500	2	510	0	0	
5,905	46.6	5,905	46.6	3	5.0	1	72	0	0	0	0	0	0	
1,395	69.2	1,395	69.2	0	0.0	2	60	0	0	0	0	0	0	
10,230	100.0	4,930	48.2	4	17.0	0	0	0	0	0	0	0	0	
6,438	100.0	6,438	100.0	0	0.0	1	26	0	0	0	0	0	0	
1,742	77.7	0	0.0	0	0.0	0	0	0	0	0	0	2	80	
5,497	100.0	5,497	100.0	0	0.0	3	156	0	0	0	0	14	0	
31,207	79.8	24,165	61.8	7	22	7	314	0	0	0	0	16	80	
509,701	65.7	363,866	46.9	233	339.5	134	13,421	2	560	5	910	710	2,808	