

平成30年度 月別使用電力量等の実績

諏訪湖流域下水道豊田終末処理場

	力率 (%)	最大需要 電力(kW)	使用電力量(kWh)			
			重負荷時間	昼間時間	夜間時間	計
H30. 4	100	2,801	—	828,430	904,797	1,733,227
5	100	2,688	—	760,929	1,026,175	1,787,104
6	100	2,772	—	902,407	811,319	1,713,726
7	100	3,028	447,988	438,717	911,617	1,798,322
8	100	2,969	481,665	455,023	873,445	1,810,133
9	100	2,793	401,331	382,775	877,170	1,661,276
10	100	2,890	—	875,503	808,676	1,684,179
11	100	2,747	—	815,203	841,844	1,657,047
12	100	2,906	—	860,698	989,785	1,850,483
H31. 1	100	2,873	—	813,540	1,030,142	1,843,682
2	100	2,856	—	798,164	838,690	1,636,854
3	100	2,785	—	858,308	918,275	1,776,583
計	—	—	1,330,984	8,789,697	10,831,935	20,952,616