

令和6年度 月別使用電力量等の実績

諏訪湖流域下水道豊田終末処理場

| | 力率 (%) | 最大需要 電力(kW) | 使用電力量(kWh) | | | |
|---------|-----------|----------------|------------|-----------|-----------|------------|
| | | | 重負荷時間 | 昼間時間 | 夜間時間 | 計 |
| R 6 . 4 | 100 | 2,814 | — | 701,456 | 743,659 | 1,445,115 |
| 5 | 100 | 2,737 | — | 644,413 | 834,358 | 1,478,771 |
| 6 | 100 | 2,912 | — | 753,263 | 737,408 | 1,490,671 |
| 7 | 100 | 2,800 | 409,514 | 384,132 | 762,860 | 1,556,506 |
| 8 | 100 | 2,835 | 403,207 | 376,768 | 750,974 | 1,530,949 |
| 9 | 100 | 2,436 | 343,350 | 322,224 | 751,828 | 1,417,402 |
| 10 | 100 | 2,464 | — | 749,651 | 711,228 | 1,460,879 |
| 11 | 100 | 2,800 | — | 701,477 | 731,906 | 1,433,383 |
| 12 | 100 | 2,247 | — | 678,573 | 765,163 | 1,443,736 |
| R 7 . 1 | 100 | 2,408 | — | 659,876 | 813,001 | 1,472,877 |
| 2 | 100 | 2,387 | — | 658,266 | 726,124 | 1,384,390 |
| 3 | 100 | 2,457 | — | 757,526 | 796,278 | 1,553,804 |
| 計 | — | — | 1,156,071 | 7,387,625 | 9,124,787 | 17,668,483 |